

SCHEDULE OF QUANTITY

Tender Inviting Authority: SE (LBM) on behalf of DIRECTOR , NATIONAL INSTITUTE OF DESIGN ANDHRA PRADESH

Name of Work: SITC of IT Equipments (Sh- UPS and Batteries) at NID AP

Contact No: Office of the Senior Engineer (LBM), NID AP EEE Building, Acharya Nagarjuna University,
Nagarjuna Nagar , Guntur - 522510, Andhra Pradesh
Mob- 9811019425

Sl. No.	Item Description	Quantity	Units	Rate (Rs.)	Amount (Rs.)	% to be quoted (in figures)	% to be quoted (in words)
1	SITC of 1 KVA UPS Capacity VA 1000va, Capacity Watts 600Watts, Nominal Input voltage 220vac - 240vac, Input voltage range for online operation 170vac - 294vac, Auto voltage regulation 182vac - 216vac +17% & 252vac - 282vac -17%, Interface USB/ Serial, Output sockets Minimum 4nos 6A 3pin Indian Sockets with battery backup and 2nos 6A 3pin Indian sockets for Surge protection, Power saver mode Should be available, Battery VAH Minimum 216vah, Software Auto Shutdown software should be available, Display OCD Display should show: Input Voltage, Output voltage, Auto voltage regulation, Buzzer mute, Load in Watts and %, Replace battery indication, Battery charge level, Online or battery. Overload, Extended battery backup Should be able to add battery bank at any point of time to increase the battery backup Warranty 2 years on UPS and batteries, Extended warranty Optional Extended warranty including battery should be available (make- APC/Luminous or equivalent)	20	Each	5000	100000		
2	SITC of 600 VA UPS Capacity VA 600va, Capacity Watts 360Watts, Nominal Input voltage 230vac, Input voltage range 145vac - 290vac, Output sockets Minimum 3nos 6A 3pin Indian Sockets with battery backup and surge protection, Battery saver mode Should be available, Battery VAH Minimum 84vah, Warranty 2 years on UPS and batteries, Extended warranty Optional extended warranty including battery should be available, Battery charge indication Should be available(make- APC/Luminous or equivalent)	20	Each	4000	80000		
3	SITC of approved make 12V 65 AH UPS battery (SMF) with at least 2 years warranty (Amaron or Exide)	32	Each	5000	160000		
4	Buyback of old batteriees UPS battery (SMF)12V 65 AH (amaron /exide) i/c lifiting , tranSPORTING etc	-32	Each	750	-24000		
	Total amount (estimated)				316000		
Note - (use + sign for excess and - sign for below while quoting the rates)							
Name , signature and seal of the agency							